## HOOKSETT SEWER COMMISSION

HOOKSETT	
SEWER DEPARTMENT	
SEWER DEPARTMENT DATE RECEIVED // -/3-/9	<b>V</b>

## **WORKSHOP MINUTES**

NOVEMBER 5, 2019

SENSIFICATION CONTRACTOR CONTRACT	Parking and a second se
INITIAL	COMMENTS.
tion management of the second	n-m-ch-ville from the Andrew Andrew - Proposition (Andrew St. Proposition (Andrew Andrew Andr
garani DRL	Remototypessisse
-jens	
	,

The workshop started at 10:00am. Present were Chairman Sid Baines, Commissioner Frank Kotowski and Commissioner Richard Bairam.

## 10:00am

Bruce Thomas, the Town Engineer, met with the Board to request a waiver to allow the Town to connect the Fire Department floor drain manhole to the sewer system. This would be at the Riverside Drive station.

Mr. Thomas presented a GIS sketch of the proposed connection and explained that MS 4 federal drainage requirements require the Town to eliminate all illicit discharges into the Merrimack River. Currently, when the Fire Dept. washes its trucks at the Riverside street station, the water flows through floor drains to a drain manhole in front of the building. From there the flows run directly to the river, thus violating the MS 4 requirements.

He is requesting a waiver, from the Town of Hooksett Sewer Ordinances Section 2.2 (D), to allow the Town to connect this drain manhole to the sewer system sewer line that runs along the front of the building. The sewer connection would be installed per the Sewer Use Ordinance and follow accepted standard practices.

The Board agreed that a waiver would be subject to confirmation that no grease or oil would be put down the system and it would be strictly used for washing fire department vehicles.

Mr. Thomas will get confirmation from the Fire Department and get back to the Board.

No decisions were made.

## 10:30am

The Board met with Dave Scarpetti, Alden Beauchemin, Matt Barrett, Nick Brunet, Brenda Balenger and Angela Hayden to discuss possible plans for property, owned by Manchester Water Works, if it could be purchased. This parcel is located next to the Wastewater Treatment Facility. After a lengthy discussion, the Board suggested that the group set up a meeting with representatives from Manchester Water.

The workshop ended at 11:35am. No decisions were made.

Respectfully Submitted,

Clerk

PLEASE SIGN IN  Please Print!		
Name	Title	
BRENDA F	SMENGER DIRECTOR - MANCHESTER ROWING ALLIANCE	
Alick 2	RUNET PRESIDENT-MRA	
· · · · · · · · · · · · · · · · · · ·	SCAR PETTI Hooksett Communty Centra	
Math	Barrett HCC	
ALDER	EXEAUCHEUIN KEYLAND EXT.	
Angelo	Hayde MRA Board Member	

Date:\_\_\_\_\_